

CCR Rule Report: Periodic Safety Factor Assessment

Bottom Ash Pond 1 Laramie River Station Wheatland, Wyoming

Basin Electric Power Cooperative Bismarck, North Dakota

Project number: 60665977

October 12, 2021

Project number: 60665977

Quality information

Prepared by		Checked by			Verified by		Approved by	
Matthew Bloecher Geotechnical Engi	, PE (WI) ineer	Jeremy Tr Associate	homas, PE (WI)	Jeremy Thoma Associate	as, PE (WI)	Jeremy Tho Associate	mas, PE (WI)
Revision His	story							
Revision	Revision da	ate	Details		Authorized	Name	Pos	sition
Distribution		rod	Accordation /	Compo	nny Nama			
# Hard Copies	PDF Requi	red	Association /	Compa	ину мате			

Prepared for:

Basin Electric Power Cooperative 1717 East Interstate Avenue Bismarck, ND 58503

Prepared by:

AECOM 2985 South Ridge Road, Suite B Green Bay, Wisconsin 54304 aecom.com

Copyright © 2021 by AECOM

All rights reserved. No part of this copyrighted work may be reproduced, distributed, or transmitted in any form or by any means without the prior written permission of AECOM.

Table of Contents

1.	Introduction	5
2.	Periodic Safety Factor Assessment	6
3.	Certification Statement	7
Tak	oles	
Table	e 1. Summary of Periodic (5-year) Safety Factor Assessment	6

1. Introduction

This Coal Combustion Residual (CCR) Rule Report documents that Bottom Ash Pond 1 at the Basin Electric Power Cooperative Laramie River Station meets the safety factor assessment requirements specified in 40 Code of Federal Regulations (CFR) § 257.73(e).

Bottom Ash Pond 1 is an existing CCR surface impoundment as defined by 40 CFR § 257.53. The CCR Rule¹ requires that periodic safety factor assessments be completed every five (5) years. The initial safety factor assessment for the existing CCR surface impoundment was completed on October 12, 2016.

The owner or operator of the CCR unit must obtain a certification from a qualified professional engineer stating that the periodic safety factor assessment meets the requirements of 40 CFR § 257.73(e).

The owner or operator must prepare a safety factor assessment every five years.

¹ U.S. Environmental Protection Agency (USEPA) (2015). *Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals From Electric Utilities; Final Rule*, 40 CFR Part 257. Federal Register, Volume 80, Subpart D, April 17, 2015.

2. Periodic Safety Factor Assessment

40 CFR § 257.73(e)(1)

The owner or operator must conduct initial and periodic safety factor assessments for each CCR unit and document whether the calculated factors of safety for each CCR unit achieve the minimum safety factors specified in (e)(1)(i) through (iv) of this section for the critical cross section of the embankment. The critical cross section is the cross section anticipated to be the most susceptible of all cross sections to structural failure based on appropriate engineering considerations, including loading conditions. The safety factor assessments must be supported by appropriate engineering calculations.

- (i) The calculated static factor of safety under the long-term, maximum storage pool loading condition must equal or exceed 1.50.
- (ii) The calculated static factor of safety under the maximum surcharge pool loading condition must equal or exceed 1.40.
- (iii) The calculated seismic factor of safety must equal or exceed 1.00.
- (iv) For dikes constructed of soils that have susceptibility to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20.

An initial safety factor assessment was performed in October 2016. As part of the periodic assessment, an updated analysis has been performed to document that the calculated factors of safety for Bottom Ash Pond 1 achieve the minimum factors of safety listed in § 257.73(e)(1)(i) through (iv). The periodic assessment included evaluating multiple cross-sections of existing conditions and performing analyses at the critical (i.e. most susceptible) cross section, based on appropriate engineering considerations and calculations. The analyses used subsurface information collected from historical subsurface investigations and laboratory testing data. Engineering properties for the various material strata were selected based on the results of available field and laboratory data. The results of the safety factor assessment are listed in Table 1.

Table 1. Summary of Periodic (5-year) Safety Factor Assessment

Loading Conditions	§ 257.73(e)(1) Subsection	Minimum Factor of Safety	Calculated Factor of Safety
Maximum Storage Pool Loading	(i)	1.50	1.86
Maximum Surcharge Pool Loading	(ii)	1.40	1.87
Seismic	(iii)	1.00	1.35
Soils Susceptible to Liquefaction	(iv)	1.20	2.00

Based on this evaluation, Bottom Ash Pond 1 meets the requirements in § 257.73(e)(1).

3. Certification Statement

CCR Unit: Basin Electric Power Cooperative; Laramie River Station; Bottom Ash Pond 1

I, Jeremy Thomas, being a Registered Professional Engineer in good standing in the State of Wyoming, do hereby certify, to the best of my knowledge, information, and belief that the information contained in this CCR Rule Report has been prepared in accordance with the accepted practice of engineering. I certify, for the above referenced CCR Unit, that the periodic safety factor assessment as included in 2021 Addendum to the Reconstitution of the CCR Surface Impoundment Design Subsurface and Geotechnical Engineering Analysis dated September 2016 meets the requirements of 40 CFR § 257.73(e).

Jeremy Thomas
Printed Name
October 12, 2021
Date

